



NOTICE TO ALL FIRMS

Date: September 30, 2025

To: All Prospective Bidders

From: Maria De Los Angeles Lopez
Purchasing Agent

Re: Addendum Number 2
IFB # C1671 – Business Center Replacement of
Air Handler Units AC-1B, AC-2B, AND AC-3B

Questions

Q1. We'd like to price this project with Carrier Custom AHU and/or MAFNA. Provide we can meet the specification and schedule, would these approved for the project?

A1. Carrier and MAFNA are not listed as an acceptable manufacturers in spec Section 23 12 05. FIT accepts equipment that are approved equals.

Q2. Please provide allowance details, if any?

A2. No allowances.

Q3. Please confirm the exact scope of existing ductwork to be cleaned as the spec/drawings are not clear. If the ductwork to be cleaned is not shown on the drawings and called out specifically on drawing notes, please advise sqft of ductwork to be utilized for bidding estimation purposes.

A3. All supply and return ductwork related to AHU-1B, AHU-2B and AHU-3B system within the mechanical room on the 10th floor.

THIS ADDENDUM IS PART OF THE CONTRACT DOCUMENT AND SHALL BE INCLUDED WITH YOUR REQUEST FOR PROPOSAL SUBMITTAL. YOUR SIGNATURE BELOW WARRANTS THAT YOU UNDERSTAND THIS ADDENDUM AND THAT YOU HAVE MADE THE APPROPRIATE ADJUSTMENTS IN YOUR PROPOSAL AND CALCULATIONS.

Signature

Print Name and Title of Authorized Representative

Print Name of Company/Partnership/Individual

Date