



**Fashion Institute  
of Technology**

Seventh Avenue at 27 Street  
New York City 10001-5992  
www.fitnyc.edu

**Purchasing Department  
227 West 27<sup>th</sup> Street  
New York, NY 10001  
Purchasing Dept. Tel. 212-217-3630  
Purchasingbids@fitnyc.edu**

## **NOTICE TO ALL FIRMS**

Date: July 23, 2025  
To: All Prospective Bidders  
From: Candida Poinsette  
Assoc. Director, Procurement Services  
Re: Addendum Number 2  
RFP C1672 – Feldman Center Waterside Economizer

In this addendum you will find the final questions received during the RFI period. Please review them carefully and ensure they are considered when preparing your proposal. Please acknowledge receipt of this addendum and include it with your proposal submission.

### **Questions/Answers**

Q1. Per Drawing A-003 between grids 18&21 the noted W8X18 should be (Existing) W16X31?

A1. The existing beams are W16x31 and the new beams are W8x18. See section 1 on A-004.

Q2. Per Drawing A-003 between grids 21&23 the unsized (added) beams should be W8X18?

A2. The new beams are W8x18. See response 1.

Q3. The clear Space for Bracing angles is approximately 1'-0" , Can we substitute a single 3/8" gusset plate to be field welded to 1+SS post & W18 beam?

A3. All proposed changes will be reviewed during shop drawing process.

**YOUR SIGNATURE BELOW WARRANTS THAT YOU UNDERSTAND THIS ADDENDUM AND THAT YOU HAVE MADE THE APPROPRIATE ADJUSTMENTS IN YOUR PROPOSAL AND CALCULATIONS.**

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Print Name and Title of Authorized Representative

\_\_\_\_\_  
Print Name of Company/Partnership/Individual

Date \_\_\_\_\_